

C/M or P/M Reviewed:	<u>CONSTRUCTION JOB HAZARDS ANALYSIS</u> <i>Acoustical Ceilings (T-bar)</i>	
Building & Room(s):	Contractor/Subcontractor Name:	Rev: 2015
Project:	Date:	
Scope of Work: Installing _____ sf of T-bar / suspended ceiling		

Tasks being Performed	Hazards	Controls
<p><u><i>This is a TEMPLATE</i></u></p> <p>Install _____ square feet of T bar ceiling grid</p> <p>Mobile rolling scaffold to be used</p> <p>Lay out of main's and cross T's (on floor)</p> <p>Rotary laser to be used</p> <p>Install wall angle</p> <p>Install ceiling wires (penetration permit is required)</p> <p>Install main runners & cross T's</p> <p>Install and cut acoustic panels</p> <p>Work to be done off scaffolds</p> <p><u>If a Powder actuated tool or a Scaffold is needed.</u> <u>Add those JHA pages</u></p>	Risk of serious bodily injury or death	<p>All employees shall be trained and instructed in the safe use of tools and equipment.</p> <p>Only use the scaffolds for its intended purpose.</p> <p>Pre-shift inspections of scaffolds by a qualified person shall occur prior to the start of work or shift.</p> <p>Ensure the scaffold has been properly inspected prior to that shift.</p>
	Risk of slips, trips & falls	<p>Work area is to be kept clear of any debris, along with access/egress area's</p> <p>Housekeeping shall be maintained but not limited to hourly/daily, as site conditions change or as needed</p> <p>Be aware of your surroundings.</p> <p>Working from scaffolds over 6' without the guardrail system in place, fall protection will be required.</p> <p>Fall Protection Matrix is required when wearing Fall Protection Equipment.</p> <p>Ensure "ALL" scaffold wheels are locked when working from the mobile platform.</p>
	Risk of exposure to a laser light	<p>Ensure work area is clearly labeled with Signage stating "Laser in Use".</p> <p>Lasers shall be less than 0.5 watts</p> <p>Only necessary personnel in room while laser is operated by qualified personnel only.</p> <p>Laser level will be turned off when not in use.</p>

Employee Signatures:	Date:

Employee Signatures:	Date:

Employee Signatures:	Date:

A signed copy of this JHA must be posted while the applicable subcontractor is working on-site and be available to any employee upon request.