

C/M or P/M Reviewed:	<b><u>CONSTRUCTION JOB HAZARDS ANALYSIS</u></b> <i>Carpentry, Forming, Framing or Wood Working</i>	
Building & Room(s):	Contractor/Subcontractor Name:	Rev: 2015
Project:	Date:	

Scope of Work: **Please list the scope of work in this area (and remove these directions).**

Tasks being Performed	Potential Safety Risks/Hazards	Safety Controls / Mitigations
<p><b><u>This is a TEMPLATE</u></b></p> <p><b><u>Layout:</u></b> Layout area to be framed</p> <p><b><u>Forming or Framing:</u></b> Installing wood / metal using a Nail gun, Hammer or screw gun</p> <p><b><u>Installing anchors:</u></b> Using wedge anchors , All Threads and Bolts, Tie Downs or Powder Actuated Tool</p> <p><b><u>Tools that will be used :</u></b> Refer to Hand &amp; Power tool JHA</p> <p><b><u>House Keeping &amp; Clean-Up:</u></b></p>	Risks of injury from improper lifting	<p>All employees shall be instructed in safe lifting techniques.</p> <p>If loads are awkward, too heavy, high traffic areas, two (2) men are required for carrying loads 10' or greater.</p> <p>Only secure stable loads may be transported by hand truck or dollies. Do not exceed capacity</p> <p>Use multiple persons to transport large or heavy loads and use spotter</p>
	Risk of injuries/ cuts from improper use of tools.	<p>Employees are to be trained on the use of tools. All tools shall be inspected before use</p> <p>Keep all used razor blades in a sharps container labeled as "SHARPS"</p> <p>Proper PPE shall be worn by adjacent personnel, as required by their proximity to the work task.</p>
	Risk of exposure to a laser light	<p>Ensure work area is clearly labeled with Signage stating "Laser in Use".</p> <p>Lasers shall be less than 0.5 watts</p> <p>Only necessary personnel in room while laser is operated by qualified personnel only.</p> <p>Laser level will be turned off when not in use.</p>
	Risk of exposure to silica based products	<p>Respirators will be need required for drilling into concrete.</p> <p>A Respirator Program with medical evaluation &amp; fit test has been Submitted, Reviewed and Accepted by EHS.</p>
	Risk of injuries due to Slips, Trips & Falls	<p>Housekeeping shall be maintained but not limited to hourly/daily, as site conditions change or as needed.</p>

<b>Employee Signatures:</b>	<b>Date:</b>

<b>Employee Signatures:</b>	<b>Date:</b>

<b>Employee Signatures:</b>	<b>Date:</b>

A signed copy of this JHA **must** be posted while the applicable subcontractor is working on-site and be available to any employee upon request.