

Fire Safety Quiz

1. Which of the following fire extinguishers is used to put out Class A fires?
 - (A) CO2
 - (B) Water
 - (C) Multi-purpose dry chemical
 - **(D) Both b and c**
 - (E) Both a and b
2. Which of the following fire extinguishers is used to put out fires caused by flammable liquids?
 - (A) Class A water fire extinguishers
 - **(B) Class B carbon dioxide fire extinguisher**
 - (C) Class C dry chemical fire extinguisher
 - (D) None of the above
3. Which of the following is the acronym describing the correct sequence of using a fire extinguisher?
 - (A) PULL
 - (B) PUSH
 - **(C) PASS**
 - (D) None of the above
4. Where should you aim a fire extinguisher nozzle when putting out a fire?
 - (A) At the top of the fire
 - **(B) At the base of the fire**
 - (C) At the center of the fire
 - (D) Away from the fire

5. What can you do to help prevent a fire at work?
- **(A) Avoid using electrical equipment near flammable gases, vapors, and liquids**
 - (B) Clutter your workspace with paper and other combustibles
 - (C) Use electrical wires near flammable gases and liquids
 - (D) Avoid cleaning up oil spills and chemical spills
6. Before an emergency occurs, you should...
- (A) Be able to recognize the sound/signal of a fire or evacuation alarm
 - (B) Know the person to contact in an emergency
 - (C) Be aware of the pathways to a minimum of 2 exits from every area of the workplace
 - (D) Know the location of the fire alarms and how to use them
 - **(E) All of the above**
7. Which of the following should you NOT do during a fire emergency?
- (A) Evacuate a building through designated exit routes
 - (B) Keep fire doors shut to prevent the fire from spreading
 - (C) Crawl low under the smoke while breathing only through your nose
 - **(D) Re-enter the building without the permission of authorities**
8. During a fire, when a stairwell is unavailable because it is disabled or inaccessible, it is okay to use the elevators when exiting a building.
- (A) True
 - **(B) False**
9. Workplaces with a minimum of ____ employees need to have a written fire prevention program in place.
- (A) 5
 - **(B) 11**
 - (C) 20
 - (D) 25